

Inspection Report

Wet Work Inspection

Wet Work Inspection

Life Safety

Main	Type	Answers
1 Was Wet work permit created and reviewed?	Yes / No	Yes No
2 Identify all upstream and downstream shutoff valves	True / False	True False
3 Exercise valves before starting work where feasible	True / False	True False
4 Did you confirm liquid conveying system is properly isolated in accordance with IFC and NFPA?	True / False	True False
5 Did you verify floor drains, containment and absorbent materials are staged?	Yes / No	Yes No
6 Did you protect finished surfaces and guest areas?	Yes / No	Yes No
7 Did you notify impacted departments? (front desk, housekeeping, security, maintenance)	Yes / No	Yes No
8 Did you ensure proper tools/equipment are maintained within work area?	Yes / No	Yes No
9 Is a dedicated attendant present at all times during work?	Yes / No	Yes No
10 Are temporary caps and plugs mechanically secured?	Yes / No	Yes No
11 Is pressure testing controlled and monitored?	Yes / No	Yes No
12 Did you restore water and observe for leaks?	Yes / No	Yes No
13 Did you inspect adjacent rooms, floors below and shafts?	Yes / No	Yes No
14 Did you verify alarms, leak detection and BMS signal in working order?	Yes / No	Yes No
15 Maintain enhanced monitoring for 24 hours	True / False	True

Inspection Report

		False
16	Close permit and upload documentation	File
		File Score